

Dr Howard Cafeteria Equipment Bid Questions and Answers

- Are we required to do installation?
Storage and installation are required
- Or will this just be delivered to the Service Center?
No
- If we are required to do installation? Are we removing existing?
Not removing existing equipment
- Will utilities be in place? Electric, Drain, Plumbing, gas etc..
Yes
- Most of the equipment is very specific regarding vendor and model numbers. Will the district accept any alternates on these items?
No alternates on items with specific make and models will be accepted.
- The final item on the bid list is a three compartment sink that does mention various vendor and include Eagle Group or equal. This usually means that we can substitute a product that is equal quality of the Eagle sink. Are substitutes that are equal to the Eagle sink acceptable on this item?
Alternatives to Eagle Group can only be Advance Tabco, Aero or Atlanta Custom Fab.
- Three compartment sink specification clarification:

ITEM # 51 THREE COMPARTMENT SINK

Manufacturer: Eagle Group or equal by Advance Tabco, Aero, Atlanta Custom Fab, Universal Stainless, IEI, John Boos, or Nationwide

Model: FN2860-3-48-14/3

Sink, three compartment, stainless steel, with 48" left & right-hand drainboards, 28" front-to-back x 20"W compartment, 16"D, with 10"H splash, stainless steel open frame base, boxed crossrails, 2 set of faucet holes, 14/304 stainless steel, NSF

Provide 1" turndown at backsplash

Secure the worktable to the wall using 16ga. Stainless steel "Z" clips

Individual fabricated sink bowls welded in place-14/304

All welded construction

Side splash when located next to wall

- Is this replacing existing? If so, what are the makes and models?
It's not replacing any equipment
- Is everything being installed on the first floor?
Yes, the kitchen will be located on the first floor
- Is there a loading dock available?
There will be no loading dock at Dr Howard